

Optimized Design of Steel Transmission Line Tower by Limit State Methodology

Sai Vivek K¹ and Nagendra V²

¹Department of Civil Engineering, RVR&JC College of Engineering, Guntur-522019, India

²Engineer, Prestige Estate Projects Limited, Bangalore- 560001, India

ABSTRACT: For the transfer of high voltage power from the generating source to longer distances, "Steel Transmission Line Towers" are used to carry the transmission lines. The behaviour of the tower when subjected to wind was studied by analyzing the tower for wind load in combination with longitudinal loads due to Broken -Wire condition and Vertical Forces. Understanding the behaviour of tower and Optimum Design of members to withstand the forces are the main objectives of the present study. A 132KV Double Circuit, 4-legged, Free-Standing and Intermediate-Tangent 3-Dimensional tower was selected. After the analysis of the tower by using STAAD PRO v6i software, the tower was designed manually as well as Optimum designed using STAAD PRO v6i by following "Limit state method" as per IS: 800-2007, and was compared with conventional "working stress method".

Keywords: Broken-Wire condition, Optimum Design, Steel Transmission Line Tower, STAAD Pro and Wind Force.

I. INTRODUCTION

1.1 Increase in power stations and transmission line structures (structures used for transferring power from power generating stations to the load centers) was observed in recent past due to increase in population, machines and industrial growth which lead to demand for Extra High Voltage (EHV) in all developed and developing countries.

The EHV has given rise to the need for usage of relatively large transmission line structures such as Steel Transmission Line Towers. Transmission Line Towers constitute about 28 to 42 percent of the total cost of the Transmission Lines [1].

The tall three dimensional structures with relatively small cross-section having a large ratio between the height and the maximum width are known as *Towers*. Towers can also be termed as *Pylons*. The towers used for carrying transmission lines (wires or cables) are called *Transmission Towers* or *Transmission Line Towers*.

Towers are subjected to mechanical forces like dead load and broken wire loads as well as environmental forces such as wind, floods and earthquake. So, the towers should be designed properly i.e.; Optimum Design should be achieved by the designer and correct detailing should be provided to the site engineer.

Optimum design can be achieved through appropriate selection of height-width ratio; insulation strength (no: of insulator discs with adequate clearances); conductors & ground wires with required steel reinforcement; span, configuration & weight of tower; analysis & design method to provide strength & stability of the structure; and effective cost analysis are met. Necessary maintenance should be provided for proper functioning.

Working stress method does not consider the strength of the member beyond proportionality limit and after local yielding [2], resulting in heavier sections. Hence optimum design cannot be achieved with working stress method. Limit state methodology is a rational method [3] which overcomes the drawbacks of working stress method and provides optimum sections. Limit state method is followed in this thesis. Manual design does not lead to optimum sections because often higher sections than required may be selected. So with the help of computers, programs developed based on fuzzy logic of optimization which resulted saving in tower weight of 6% [4] and reliability based optimization in which the weight of the optimal tower accounting for reliability as a constraint for both 110 and 220 kV tangent towers is only 3-4% heavier than the tower designed using the conventional method [5] or other techniques must be used to obtain an optimum section which the structural engineers may not be able to follow practically. Fortunately the latest design soft wares are capable of arriving at optimum section following the desired code of designer such as STAAD.

Tower structure with least weight is directly associated in reduction of the foundation cost [6]. Configuration of the structure of the tower plays a vital role in its performance especially while considering

eccentric loading conditions. The bottom tier members have major role in performance of the tower in taking axial forces and the members supporting the cables are likely to have localized role. The vertical members are more prominent in taking the loads of the tower than the horizontal and diagonal members. The members supporting the cables at higher elevation are likely to have larger influence on the behavior of the tower structure. The effect of twisting moment of the intact structure is not significant. [7]. The three legged tower members are subjected more force and deflection when compared with four legged tower, but requires less area as well as resulted in less weight[8]. For towers up to 50m height, Y bracing resulted in less joint displacement and is economical [9].

The triangular tower is found to have little higher amount of axial forces in the leg members in comparison with the square tower [10].

II. TOWER CONFIGURATION

2.1The tower studied in this thesis is a Four-Legged square shaped 132 KV Double Circuit Steel Transmission Line Tower. The tower has 6 conductors and 1 ground wire. Six cross-arms are provided to carry the conductors and clamp of the tower carries the ground wire. The tower is a Free-standing/Self-supported single cantilever structure fixed at the base meaning that no guys are used to support the tower. The tower is assumed as an intermediate, Tangent tower (Angle of deviation with respect to adjacent towers = 0-2 deg.). X-X bracing system is adapted. The insulators are suspension type insulators. All the members are to be provided with steel angle sections. Figure.1 depicts the 132 KV tower with above configurations.



Figure 1: 132 KV GNT-TDK DC TOWER

2.2 The other basic details required for calculation loads are as follows:

- Site : Guntur (wind zone : 5)
- Type of land : Exposed terrain and less obstruction
- Conductor : 30/3.00mm Al + 7/3.00mm Steel ACSR conductor
Overall diameter = 21mm; Maximum Working Tension = 3640Kg;
Unit Weight = 9.77 N/m [11]
- Ground Wire : 7/4.06mm Steel Strand
Overall Diameter = 12.2mm; Maximum Working Tension = 2960 Kg;
Unit Weight = 7.52 N/m [12]
- Temperature : 32°c (Maximum Temperature = 60°c and Minimum Temperature = 20°c)
- Area : 36m² (6m X 6m) ⇒ Base width = 6m.
- Height : 21m (Refer section 2.3)
- Span : 330m

2.3 Determination of Height and Top hammer width:

2.3.1The factors governing the height of the tower are:

1. Minimum permissible ground clearance (h1)

2. Maximum sag (h2)
3. Vertical spacing between conductors (h3)
4. Vertical clearance between ground wire and top conductor (h4)

Thus the total height of the tower is given by

$$H = h1 + h2 + h3 + h4 \text{ (m)}$$

- For 132KV DC tower clearance above the lowest point of the conductor as 6.10m = h1. [13]
- The conductors are subjected to sagging during hot climate. The tower height should be determined by considering the maximum sag (sag at peak hot climate). By considering the temperature and the external forces acting on the conductor (horizontal force due to wind, vertical force due to weight of conductor and ice formation) the amount of sag is calculated by catenary method. For a maximum temperature of 60°C, sag can be assumed as 6m = h2 [1].
- Based upon the value of sag the vertical spacing required between the conductors is calculated by Swedish Empirical formula Vertical Spacing between the top most and lowest conductors [1] is $6.5\sqrt{S} + 0.7E$.
Where S = Sag in cm E = Line Voltage in KV. From the formula h3 = 5.9m.
- Considering the shielding angle (angle which the line joining the ground wire and the outer most conductor makes with the vertical) required for interruption of direct lightning strikes at the ground and the minimum mid span clearance between the ground wire and the top power conductor h4= 3m. H = 21m.

- 2.3.2** The top hammer width of the tower is one-third (1/3) times the base width based upon the condition that "The intersection of the tower legs should be above the CG (resultant) of the entire loads so that the resultant load is carried both braces and leg members. Hence top hammer width = (1/3)*6 = 2m.

III. LOAD CALCULATION

3.1 Classification of Load and Load combinations

Before load calculation, the loads acting and load combinations can be classified as shown below:

The loads acting on the tower are:

- a) Vertical Loads: These loads include weight of the tower, weight of Conductors and workman.
- b) Transverse loads: These loads include wind force.
- c) Longitudinal Loads: These loads include forces induced in conductors under broken wire conditions

The load combinations are:

- a) Normal Condition (Vertical and Transverse Loads)
- b) Ground Wire Broken Condition (Vertical ,Transverse and Longitudinal Load at clamp)
- c) Top Conductor Broken Condition (Vertical, Transverse and Longitudinal load at top cross-arm)

3.2 Calculation of Wind Pressure [14, 15]

- Reliability level = 1 (as 132 KV < 400 KV)
- Basic wind Speed $V_b = 50$ m/s (as Wind Zone = 5)
- V_R (Meteorological Reference wind speed) = $V_b / \{ k_o \text{ (code)} \} = 50 / 1.375 = 36.3636$ m/sec
- Design Wind Speed $V_d = V_R \times K_1 \times k_2$
From table 2 of IS: 802 $K_1 = 1.00$ (Risk Coefficient), $K_2 = 1.08$ (for Open Terrain)
 $V_d = 36.36 \times 1 \times 1.08 = 39.2688$ m/sec = 40 m/sec
- Design Wind Pressure $P_d = 0.6 V_d^2 = 0.6 \times (40)^2 = 960$ N/mm² = assume 1000 N/mm²
Therefore Wind Pressure on Tower = 1000 N/mm² = 100 Kg/mm²

Transverse Load at G.W Level [1, 14]

a) Under Normal Condition:

1) Due to Wind on G.W = $2/3 \times d \times \text{Span} \times \text{Wind Pressure}$
 $= 2/3 \times 0.0122 \times 330 \times 1000$
 $= 269$ Kg

2) Due to Deviation = $2T \sin \theta/2 = 2 \times 2960 \times \sin 2/2 = 107$ Kg

3) Due to wind on clamp = 1 Kg

Total Load = $269 + 107 + 1 = 377$ Kg = 3.770 KN

b) Broken Wire Condition: $(269/2) + (107/2) + 1 = 189$ Kg = 1.89 KN

Transverse Load at Conductor Level [1, 14]

a) Normal Condition

1) Due to Wind on conductor = $2/3 \times d \times \text{span} \times \text{wind pressure}$

$$= 2/3 \times 0.021 \times 330 \times 100 = 462 \text{ kg}$$

$$2) \text{ Due to Deviation} = 2T \sin \theta/2 = 2 \times 3640 \times \sin 2/2 = 127.5 \text{ Kg}$$

3) Due to wind on insulator string

For 132 KV, length of suspension insulator string = 168 cm [16, 17]

No: of Porcelain discs (255 x 146 mm) = 9 discs

Diameter of each disc = 25.5cm

$$\text{Projected area of insulator string} = 168 \times 25.5 = 0.4284 \text{ m}^2$$

$$\text{Effective area for wind load assumed} = 50 \% = 0.2142 \text{ m}^2$$

Computed Wind load on insulator string for wind pressure of 100 Kg/mm²

$$= 100 \times 0.2142 = 21.42 \text{ Kg} = 25 \text{ Kg (assume.)}$$

$$4) \text{ Equivalent load at conductor level due to wind on tower} = (1/3) \times 4620 \text{ N} \\ = 160 \text{ Kg}$$

$$\text{Total Transverse load} = 462 + 127.5 + 25 + 160 = 775 \text{ Kg} = 7.750 \text{ KN}$$

$$b) \text{ Broken Wire Condition} = (462/2) + (127.5/2) + (25) + 160 = 480 \text{ Kg} = 4.80 \text{ KN}$$

Longitudinal Loads [1, 14]

1) Normal Condition = 0

2) Broken Wire Condition

Ground wire = 2960 Kg

Conductor = 60% X 3640 = 2184 Kg (50% by code+ 10% by practical cons.)

Vertical Loads [1, 14]

a) Conductor – Normal condition

$$\text{Weight of one span} = 0.977 \times 350 = 322 \text{ Kg} \quad (0.977 \text{ kg/m} = \text{unit wt of conductor ACSR})$$

$$\text{Weight due to weight span} = 25\% \text{ of wt of one span} = (25/100) \times 322 = 80.5 \text{ Kg}$$

Weight of two men with tools = 140 Kg

Weight of the insulator string = 91 Kg

$$\text{Total} = 322 + 80.5 + 140 + 91 = 634 \text{ Kg}$$

b) Conductor Broken Wire Condition

$$\text{Weight of half span} = (322 \times 50 \%) = 161 \text{ Kg}$$

$$\text{Weight of weight span} = (50\% \times 80.5) = 40.25 \text{ Kg}$$

Weight of two men with tools = 140 Kg

Weight of insulator string = 91 Kg

$$\text{Total} = 432.25 \text{ Kg} = 433 \text{ Kg}$$

Torsional Load [1, 14]

$$2T \times 2 = 2184 \times (1+2.50)$$

$$4T = 2184 \times 3.50$$

$$T = ((2184 \times 3.50)/4) = 1911 \text{ Kg}$$

a) Ground Wire

$$\text{Weight of on span} = 0.752 \times 330 = 248 \text{ Kg}$$

$$\text{Weight of weight span} = 62 \text{ Kg} = ((25/100) \times 248)$$

Weight of two men with tools = 140 Kg

$$\text{Total} = 450 \text{ Kg}$$

$$b) \text{ Under Broken Wire Condition Vertical Load} = (50\% \times 248) + (50\% \times 62) + 140$$

$$= 124 + 31 + 140 = 295 \text{ Kg}$$

3.3 Calculated Load and Load combinations

Finally the load combinations for 132Kv Dc tower are

Load Combination 1: Normal Condition : At Cross Arms $F_x = 7.76 \text{ KN}$, $F_y = -6.34 \text{ KN}$

At Clamp $F_x = 3.78 \text{ KN}$, $F_y = -4.5 \text{ KN}$

Load Combination 2: Ground Wire Broken : At Cross Arms $F_x = 7.76 \text{ KN}$, $F_y = -6.34 \text{ KN}$

At Clamp $F_x = 1.9 \text{ KN}$, $F_y = -6.34 \text{ KN}$, $F_z = -29.6 \text{ KN}$

Load Combination 3(Top – Left Conductor Broken): At Top-Left Cross Arm

$F_x = 4.8 \text{ KN}$, $F_y = -4.34 \text{ KN}$, $F_z = -21.84 \text{ KN}$

: At other Cross Arms

$F_x = 7.76 \text{ KN}$, $F_y = -6.34 \text{ KN}$

: At Clamp

$F_x = 3.78 \text{ KN}$, $F_y = -4.5 \text{ KN}$

IV. ANALYSIS

4.1 The analysis has been carried out using STAAD PRO v6i software which is based on stiffness method. The members are modeled as one dimensional member. As tower is a space- truss, the internal force in the members is axial force only i.e.; either Tension or Compression.

4.2 The geometry and different load combinations assigned are shown in the figures below.




Figure 2: Load Combination 1




Figure 3: Load Combination 2




Figure 4: Load Combination 3

4.3 The member forces are given in Table 1

Table 1: Member Forces

COLUMN MEMEBRS	MAX. COMPRESSIVE FORCE (KN)	MAX. TENSILE FORCE(KN)
INCLINED COLUMN MEMBERS		
1		67.01
7		64.53
11		61.28
15	4.10	
19	17.56	50.33
23	30.33	39.94
4	146.27	
8	142.79	
12	140.21	
16	136.67	
20	131.51	
24	123.25	
172		124.83
168		121.92
164		119.34
160		115.81
156		110.65
152		102.39
173	88.65	
169	86.18	
165	82.93	
161	78.47	
157	71.98	
153	61.58	
VERICAL COLUMN MEMBERS		
25	39.06	19.32
26	32.20	21.03
27	34.17	
28	29.46	
29	12.30	
42	103.33	
43	76.13	
44	55.37	

45	40.08	
46	13.75	
128		71.69
129		68.44
130		43.46
131		25.56
132		20.94
145	51.80	
146		29.51
117	9.88	6.65
148	16.42	14.93
149		19.49
HORIZONTAL MEMBERS (HAMMER MEMBERS)		
53		8.63
30	16.84	
87	2.13	
133	19.40	
86	3.84	
41		12.53
100	1.66	
144	17.49	
CROSS ARM MEMBERS		
113	15.79	
48		6.51
47	9.88	
114		13.29
115		10.31
49	9.88	
116		7.02
50		6.86
117	9.88	
51	19.57	
118		23.13
52	14.22	
122	7.43	
123		13.29
56		4.40
57		6.51
124	4.09	
125		9.46
59	1.07	
58	1.50	
61		7.26
60	2.16	
127		6.51
126	1.50	
CLAMP MEMBERS		
120		15.22
121		13.26
54	15.29	
55	17.25	
BRACING MEMBERS		
170		2.67
171	2.67	
174		2.67
175	2.67	
176		3.10
177	3.10	
166		3.10
167	3.10	
162		3.70
195	3.70	

163	3.70	
194		3.70
158		4.60
159	4.60	
193	4.60	
192		4.60
154		6.08
155	6.08	
191	6.08	
190		6.08
150		8.88
189	8.88	
151	8.88	
188		8.88
134		30.46
231		15
135	15	
230		30.46
136	8.10	
137	16.99	
233		16.99
232		8.10
138	8.21	
139		6.58
235	6.58	
234		8.21
140		13.18
141	17.80	
237		17.80
236	13.18	
142	12.56	
143	14.92	
239		14.92
238		12.56
178		6.56
3	6.56	
179	6.56	
2		6.56
5		7.62
6	7.62	
181	7.62	
180		7.62
9		9.10
10	9.10	
13		11.30
14	11.30	
183	11.30	
182		11.30
17		14.93
18	14.93	
185	14.93	
184		14.93
21		21.82
22	21.82	
187	21.82	
186		21.82
220		28.74
221	10.48	
32		10.48
31		28.74
222	28.74	
223	28.23	
34		28.23
224		16.43
225		15.56
36	15.56	

35	16.43	
226		22.51
227	12.82	
38		12.82
37		22.51
106	2.91	
203		2.91
69		2.91
213	2.91	
108	3.38	
63		3.37
197		3.37
215	3.38	
104	4.03	
65		4.03
199		4.03
211	4.03	
112	5.01	
62	4.36	
202		5.01
219	5.01	
111	6.61	
73		6.61
207		6.61
218	6.61	
103	9.66	
72		9.66
206		9.66
210	9.66	
88	7.46	
89	17.49	
251	17.49	
250	7.46	
252		12.11
253		7.25
91		7.25
90		12.21
254		7.32
255	11.59	
94	11.59	
93		7.32
256		8.75
257	9.75	
96	9.75	
95		8.75
259		9.59
98	8.30	5.28
258	8.30	
99		9.59
66	3.75	
105		3.75
212		3.75
200	3.75	
62	4.36	
107		4.36
214		4.36
196	4.36	
64	5.20	
101		5.20
208		5.20
198	5.20	
67	6.46	
109		6.46
216		6.46
201	6.46	
110		8.54

70	8.54	
204	8.54	
217		8.54
102		12.48
71	12.48	
205	12.48	
209		12.48
75	17.17	
74		19.37
240	19.37	
241		17.17
243	16.61	
242		19.69
76	19.69	
77		16.61
79		18.83
245	17.90	
80		17.90
224		20.91
247		15.40
246	20.91	
81		20.91
82		15.40
84		14.08
249	10.11	
85		10.11
248	14.08	

4.4 The displacements or the deformations of tower under the action of loads convey the behavior or response of tower. The deflections for the load combinations are presented below.




Figure 5: Load combination 1




Figure 6: Load combination 2




Figure 7: Load Combination 3

4.5 Maximum X- displacement = 63.1698 mm at clamp node under load combination 1. Maximum Y displacement = 15.9 mm at top cross arm nodes under load combination 1. Maximum Z- displacement = 9.3mm at clamp node under load combination 2.

4.6 The maximum deflection for small angle tower is $H/100$ [1]. So for 21m tower, maximum deflection is 210mm. As 63.1698mm < 210mm, the deflection was well in control.

V. LIMIT STATE DESIGN OF MEMBERS [1, 2, 3 and 18]

5.1. MANUAL DESIGN

Single-Angle sections are provided for all members. The column members are assumed as continuous single angle members. So $k = 1.0$. [14]

5.1.1 INCLINED COLUMN MEMBERS (loaded concentrically)

a) For Compression

Maximum compressive force = 146.27KN, Factored Force = $1.5 \times 146.27 = 219.405$ KN

Maximum unsupported length of the member $L = 2.54$ m

Initially assume KL/r as 100 and buckling class curve for single angle is 'c'.

Hence $f_{cd} = 107$ N/mm²

Area required = $[219.405 \times (10^3)] / [107] = 2050.51 = 2050$ mm²

Provide 130 X 130 X 12 @ 23.5 kg/m; Area = 2990 mm²; $r_v = 25.6$ mm

$KL / r_v = (1 \times 2.54 \times 10^3) / 25.6 = 99.2 < 120$ **Ok**

$K=1$ as the leg members are continuous members and the member is a single angle.

$\lambda = \sqrt{(f_y / f_{cc}), f_{cc} = \pi^2 E / (KL/r)^2}$

$= \sqrt{(99.2^2 \times 250) / (3.14^2 \times 2 \times 10^5)} = 1.116$

$\phi = 0.5 [1 + \alpha(\lambda - 0.2) + \lambda^2] = 0.5 [1 + (0.49 \times (1.116 - 0.2)) + 1.116^2] = 1.347$

$F_{cd} = (f_y / \gamma_{m0}) / [\phi + \sqrt{(\phi^2 - \lambda^2)}] \leq f_y / \gamma_{m0}$
 $= (250 / 1.1) / [1.347 + \sqrt{(1.347^2 - 1.116^2)}] = 108.15$ N/mm²

Where $f_y / \gamma_{m0} = 250 / 1.1 = 227.27$ N/mm²

Therefore $F_{cd} = 108.15$ N/mm² < 227.27 N/mm²

$P_d = A_e f_{cd} = 2990 \times 108.15 = 323.3$ KN > 219.405KN **Hence Ok**

b) For Tension

Force acting = 124.83 KN; Factored Force = $1.5 \times 124.83 = 187.245$ KN

$KL / r_v = (1 \times 2.54 \times 10^3) / 25.6 = 99.2 < 400$ **Ok**

Assume two bolts at each end of diameter 20mm. Bolt hole diameter = $20 + 2 = 22$ mm

Design strength due to rupture

$T_{dn} = 0.9 f_u A_n / \gamma_{m0} = [0.9 \times \{2990 - (2 \times 22 \times 12)\} \times 410] / 1.25 = 726.0$ KN

Design strength due to yielding

$T_{dg} = (2990 \times 250) / 1.1 = 679.54$ KN

Therefore 679.54 KN > 187.245 KN **Hence Ok**

5.1.2 VERTICAL COLUMN MEMBERS (loaded concentrically)

a) For Compression

Maximum compressive force = 103.33 KN

Factored Force = 1.5 X 103.33 = 154.95 KN

Unsupported Length = 1.5 m

Initially assume KL/r as 100 and buckling class curve for single angle is 'c'.

Hence $f_{cd} = 107 \text{ N/mm}^2$

Area required = $[154.95 * (10^3)] / [107] = 1448.13 \text{ mm}^2$

Provide 80 X 80X12 @ 14 kg/m; Area = 1780 mm², $r_v = 15.4 \text{ mm}$

$KL / r_v = (1 \times 1.5 \times 10^3) / 15.4 = 97.4 < 120$ **Ok**

$\lambda = \sqrt{(f_y/f_{cc}), f_{cc} = \pi^2 E / (KL/r)^2}$

$= \sqrt{(97.4^2 \times 250) / (3.14^2 \times 2 \times 10^5)} = 1.09$

$\phi = 0.5 [1 + \alpha(\lambda - 0.2) + \lambda^2] = 0.5 [1 + (0.49 \times (1.09 - 0.2)) + 1.09^2] = 1.3121$

$F_{cd} = (f_y / \gamma_{mo}) / [\phi + \sqrt{(\phi^2 - \lambda^2)}] = \chi f_y / \gamma_{mo} \leq f_y / \gamma_{mo}$
 $= (250 / 1.1) / [1.3121 + \sqrt{(1.3121^2 - 1.09^2)}] = 111.27 \text{ N/mm}^2 \leq 229.22 \text{ N/mm}^2$

$P_d = A_e f_{cd} = 1780 \times 111.27 = 198.06 \text{ KN} > 154.95 \text{ KN}$ **Hence Ok**

b) For Tension

Force = 71.69 KN

Factored Force = 1.5*71.69 = 107.535 KN

$KL/r_v = 97.4 < 400$ **Ok**

Design strength due to rupture

$T_{dn} = [0.9 * \{1780 - (2 * 22 * 12)\} * 410] / 1.25 = 369.5 \text{ KN}$

Design strength due to yielding

$T_{dg} = (1780 * 250) / 1.1 = 404.54 \text{ KN}$

Therefore 369.5KN > 71.69 KN **Hence Ok**

5.1.3 BRACING MEMBERS (loaded through one leg)

a) For Compression

Maximum compressive force = 30.46 KN

Factored Force = 1.5 * 30.46 = 45.69KN

Unsupported Length = 3.28 m

Initially assume KL/r as 100 and buckling class curve for single angle is 'c'.

Hence $f_{cd} = 107 \text{ N/mm}^2$.

Area required = $[45.69 * (10^3)] / [107] = 427 \text{ mm}^2$

Provide 70X70X5 @ 5.3kg/m; Area = 677mm², $r_v = 13.6 \text{ mm}$

$L / r_v = (3.28 \times 103) / 13.6 = 241.17 > 120$ and $< 200 \therefore K = 1$

$KL/r_v = 241.17 < 250$

Then $(b_1 + b_2) / 2t = (70 + 70) / (2 * 5) = 14$

And $\epsilon = 1.0$ and $\epsilon (3.14^2 E / 250)^{0.5} = 88.86$

And $\lambda_v = (L/r_v) / \epsilon (\pi^2 E / 250)^{0.5} = 241.17 / 88.86 = 2.714$

And $\lambda_\phi = [(b_1 + b_2) / 2t] / \epsilon (\pi^2 E / 250)^{0.5} = 14 / 88.86 = 0.15$

And $\lambda_{e\phi} = (k_1 + k_2 \lambda_v^2 + k_3 \lambda_\phi^2)^{0.5} = [0.20 + (0.35 * 2.714^2) + (20 * 0.15^2)]^{0.5} = 1.79$

Where $k_1 = 0.20$, $k_2 = 0.35$ and $k_3 = 20$ assuming that number of bolts in end connection is greater than or equal to 2.

$\phi = 0.5 [1 + \alpha(\lambda_e - 0.2) + \lambda_e^2] = 0.5 [1 + (0.49 \times (1.79 - 0.2)) + 1.79^2] = 1.99$

And $\chi = 1 / [\phi + \sqrt{(\phi^2 - \lambda_e^2)}] = 1 / \sqrt{(1.99^2 - 1.79^2)} = 1.15$

And $f_{cd} = \chi f_y / \gamma_{mo} = (1.15 * 250) / 1.1 = 261.36 \text{ N/mm}^2$

$P_d = A_e \times f_{cd} = 677 * 261.36 = 176.94 \text{ KN} > 45.69 \text{ KN}$ **Hence Ok**

Design of end connection

For shear plane out of bolt threads

$V_{nsb} = V_{nsb} = (f_{ub} / \sqrt{3}) * (n_n A_{nb} + n_s A_{sb}) = (400 / \sqrt{3}) * (1 * 314) = 72515 \text{ N}$

$V_{dsb} = 72515 / 1.25 = 58012 \text{ N}$

$e/3d_0$, $(p/3d_0 - 0.25)$, f_{ub}/f_u , 1.0 = $40/(3*21.5)$, $(60/(3*21.5) - 0.25)$, $400/410$, 1.0

($e = 40$, $p = 60$, $d_0 = 22$, $f_{ub} = 400$, $f_u = 410$)

$K_h = \text{least of } [e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*21.5), (60/(3*21.5) - 0.25), 400/410, 1.0]$

$K_h = 0.620$

$V_{npb} = 2.5 k_b d t f_u = 2.5 * 0.620 * 20 * 5 * 410 = 63550 \text{ N}$

$V_{dpb} = 63550 / 1.25 = 50840 \text{ N}$

No. of Bolts required = $(45.69 * 1000) / \text{least of } (50840 \text{ N}, 58012 \text{ N})$

$= (45690 / 50840) = 0.89 \approx 3$

Minimum number of bolts to be provided as per IS: 800-2007 is 2.

So, provide 3 black bolts of 20 mm diameter of 60 mm spacing at end connection to gusset of 14mm thick. Edge distance = 40mm.

b) For Tension

Force = 28.74 KN

Factored Force = 1.5*28.74 = 43.11 KN

$KL/r_v = 241.17 < 400$

Ok

$V_{nsb} = (400/\sqrt{3}) * (314) = 72515 \text{ N}$

$V_{dsb} = 72515/1.25 = 58041 \text{ N}$

$e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*21.5), (60/(3*21.5)-0.25), 400/410, 1.0$

($e=40, p=60, d_0=22, f_{ub}=400, f_u=410$)

$K_h = \text{least of } [e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*21.5), (60/(3*21.5)-0.25), 400/410, 1.0]$

$K_h = 0.620$

$V_{npb} = 2.5 k_b d t f_u = 2.5 * 0.620 * 20 * 5 * 410 = 63550 \text{ N}$

$V_{dpb} = 63550/1.25 = 50840 \text{ N}$

No. of Bolts required = $(43.11 * 1000) / \text{least of } (58041 \text{ N}, 50840 \text{ N})$

= $(43110 / 50840) = 0.89 \approx 3 \text{ bolts}$

Minimum number of bolts to be provided as per IS: 800-2007 is 2.

So, provide 3 black bolts of 20 mm diameter of spacing 60mm at end connection to gusset of 14mm thick. Edge distance = 40mm.

Design strength due to rupture

$L_c = 2 * 60 = 120 \text{ mm}$

$B_s = W + W_1 - L = 70 + 40 - 5 = 105 \text{ mm}$

$\beta = 1.4 - [0.076 (w/t) (f_y / f_u) (b_s / L_c)] \leq (f_y \gamma_{m0} / f_y \gamma_{m1})$

= $1.4 - [0.076 * (70/5) * (250/410) * (105/120)]$

= $0.83 \leq (f_y \gamma_{m0} / f_y \gamma_{m1})$

= $0.83 \leq 1.44 \text{ and } \geq 0.7$

ok

$T_{dn} = \{ [0.9 * (70 - 2.5 - 22) * 5 * 410] / 1.25 \} + \{ [0.83 * (70 - 2.5) * 5 * 250] / 1.1 \}$

= $67158 + 63664.77 = 130.8 \text{ KN}$

Design strength due to yielding

$T_{dg} = (677 * 250) / 1.1 = 153.86 \text{ KN}$

Design Strength due to Block Shear

$A_{vg} = (2 * 60 + 40) * 5 = 800 \text{ mm}^2$

$A_{vn} = (160 - 2.5 * 22) * 5 = 525 \text{ mm}^2$

$A_{tg} = (40 * 5) = 200 \text{ mm}^2$

$A_{tn} = (40 - 0.5 * 22) * 5 = 145 \text{ mm}^2$

$T_{db1} = [(A_{vg} * f_y) / (\gamma_{m0} * \sqrt{3})] + [(0.9 * A_{tn} * f_u) / (\gamma_{m1})]$

= $[(800 * 250) / (1.1 * \sqrt{3})] + [(0.9 * 145 * 410) / (1.1)] = 153.54 \text{ KN}$

$T_{db2} = [(0.9 * A_{vn} * f_u) / (\gamma_{m1} * \sqrt{3})] + [(A_{tg} * f_y) / (\gamma_{m0})]$

= $[(0.9 * 525 * 410) / (1.25 * \sqrt{3})] + [(200 * 250) / 1.1] = 134.93 \text{ KN}$

$T_{db} = 134.93 \text{ KN}$

Therefore $134.93 \text{ KN} > 43.11 \text{ KN}$

Hence Ok

5.1.4 CROSS ARM MEMBERS (loaded through one leg)

a) For Compression

Maximum compressive force = 19.57 KN

Factored Force = 1.5 * 19.57 = 29.355 KN

Unsupported Length = 3m

Initially assume KL/r as 100 and buckling class curve for single angle is 'c'.

Hence $f_{cd} = 107 \text{ N/mm}^2$.

Area required = $[29.355 * (10^3)] / [107] = 274.345 \text{ mm}^2$

Provide 65 X 65 X 4 @ 4kg/m Area = 504mm², $r_v = 12.6 \text{ mm}$

For cross- arm members $K=1$.

$KL / r_v = (1 * 3 * 10^3) / 12.6 = 238.09 < 250$

Hence Ok

Then $(b_1 + b_2) / 2t = (65 + 65) / (2 * 4) = 16.25$

And $\epsilon = 1.0$ and $\epsilon (3.14^2 E / 250)^{0.5} = 88.86$

And $\lambda_v = (L / r_v) / \epsilon (\pi^2 E / 250)^{0.5} = 238.09 / 88.86 = 2.67$

And $\lambda_\phi = [(b_1 + b_2) / 2t] / \epsilon (\pi^2 E / 250)^{0.5} = 16.25 / 88.86 = 0.18$

And $\lambda_e = (k_1 + k_2 \lambda_v^2 + k_3 \lambda_\phi^2)^{0.5} = [0.20 + (0.35 * 2.67^2) + (20 * 0.18^2)]^{0.5} = 1.82$

$$\phi = 0.5 [1 + \alpha(\lambda - 0.2) + \lambda^2] = 0.5 [1 + (0.49 \times (1.82 - 0.2)) + 1.82^2] = 2.55$$

$$\text{And } \chi = 1 / [\phi + \sqrt{(\phi^2 - \lambda^2)}] = 1 / \sqrt{(2.55^2 - 1.82^2)} = 0.55$$

$$\text{And } f_{cd} = \chi f_y / \gamma_{m0} = (0.55 \times 250) / 1.1 = 125 \text{ N/mm}^2$$

$$P_d = A_c \times f_{cd} = 504 \times 125 = 63 \text{ KN} > 25 \text{ KN} \quad \text{Hence Ok}$$

Design of end connection

$$V_{nsb} = V_{nsb} = (f_{ub} / \sqrt{3}) * (n_n A_{nb} + n_s A_{sb}) = 400 / \sqrt{3} * (1 * 314) = 72515 \text{ N}$$

$$V_{dsb} = 72515 / 1.25 = 58012 \text{ N}$$

$$e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*22), (60/(3*22)-0.25), 400/410, 1.0$$

$$(e = 40, p = 60, d_0 = 22, f_{ub} = 400, f_u = 410)$$

$$K_h = \text{least of } [e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*22), (60/(3*22)-0.25), 400/410, 1.0]$$

$$K_h = 0.620$$

$$V_{npb} = 2.5 k_b d t f_u = 2.5 * 0.620 * 20 * 4 * 410 = 50840 \text{ N}$$

$$V_{dpb} = 50840 / 1.25 = 40672 \text{ N}$$

$$\text{No. of Bolts required} = (25 * 1000) / \text{least of } (58012 \text{ N}, 40672 \text{ N})$$

$$= (25000 / 40672) = 0.614 \approx 3 \text{ bolts}$$

Minimum number of bolts to be provided as per IS: 800-2007 is 2.

So, provide 3 black bolts of 20 mm diameter of spacing 60mm at end connection to gusset of 14mm thick. Edge distance = 40mm.

b) For Tension

$$\text{Force} = 23.13 \text{ KN}$$

$$\text{Factored Force} = 1.5 * 23.13 = 34.695 \text{ KN}$$

$$Kl/r_v = 238.09 < 400$$

Ok

$$V_{nsb} = (400 / \sqrt{3}) * (314) = 72515 \text{ N}$$

$$V_{dsb} = 72515 / 1.25 = 58012 \text{ N}$$

$$e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*22), (60/(3*22)-0.25), 400/410, 1.0$$

$$(e = 40, p = 64, d_0 = 22, f_{ub} = 400, f_u = 410)$$

$$K_h = \text{least of } [e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*22), (64/(3*22)-0.25), 400/410, 1.0]$$

$$K_h = 0.620$$

$$V_{npb} = 2.5 k_b d t f_u = 2.5 * 0.620 * 20 * 4 * 410 = 50840 \text{ N}$$

$$V_{dpb} = 50840 / 1.25 = 40672 \text{ N}$$

$$\text{No. of Bolts required} = (34.695 * 1000) / \text{least of } (58012 \text{ N}, 40672 \text{ N})$$

$$= (34695 / 40672) = 0.85 \approx 3 \text{ bolts}$$

Minimum number of bolts to be provided as per IS: 800-2007 is 2.

So, provide 3 black bolts of 20 mm diameter of spacing 60mm at end connection to gusset of 14mm thick. Edge distance = 40mm.

Design strength due to rupture

$$L_c = 2 * 60 = 120 \text{ mm}$$

$$B_s = W + W_1 - L = 65 + 35 - 4 = 96 \text{ mm}$$

$$\beta = 1.4 - [0.076 (w/t) (f_y / f_u) (b_s / L_c)] \leq (f_y \gamma_{m0} / f_y \gamma_{m1})$$

$$= 1.4 - [0.076 * (65/4) * (250/410) * (96/120)]$$

$$= 0.79 \leq 1.44 \text{ and } \geq 0.7 \quad \text{Ok}$$

$$T_{dg} = (504 * 250) / 1.1 = 114.54 \text{ KN}$$

$$T_{dn} = [(0.9 * (65 - 2 * 22) * 4 * 410) / 1.25] + [(0.79 * (65 - 2) * 4 * 250) / 1.1]$$

$$= 93.6 \text{ KN}$$

Design strength due to Yielding

$$T_{dg} = (504 * 250) / 1.1 = 114.54 \text{ KN}$$

Design Strength due to Block Shear

$$A_{vg} = (2 * 60 + 40) * 4 = 640 \text{ mm}^2$$

$$A_{vn} = (160 - 2.5 * 22) * 4 = 420 \text{ mm}^2$$

$$A_{tg} = (35 * 4) = 140 \text{ mm}^2$$

$$A_{tn} = (35 - 0.5 * 22) * 4 = 96 \text{ mm}^2$$

$$T_{db1} = [(A_{vg} * f_y) / (\gamma_{m0} * \sqrt{3})] + [(0.9 * A_{tn} * f_u) / (\gamma_{m1})]$$

$$= [(640 * 250) / (1.1 * \sqrt{3})] + [(0.9 * 96 * 410) / (1.1)] = 116.17 \text{ KN}$$

$$T_{db2} = [(0.9 * A_{vn} * f_u) / (\gamma_{m1} * \sqrt{3})] + [(A_{tg} * f_y) / (\gamma_{m0})]$$

$$= [(0.9 * 420 * 410) / (1.25 * \sqrt{3})] + [(140 * 250) / 1.1] = 103.39 \text{ KN}$$

$$T_{db} = 103.39 \text{ KN}$$

$$\text{Therefore } 93.6 \text{ KN} > 30 \text{ KN}$$

Hence Ok

5.1.5 HORIZONTAL MEMBERS (loaded through one leg)

a) For Compression

Force = 19.40 KN

Factored Force = 1.5*19.40 = 29.KN

Unsupported Length = 2m

Initially assume KL/r as 100 and buckling class curve for single angle is 'c'.

Hence $f_{cd} = 107 \text{ N/mm}^2$.

Area required = $(29*1000) / 107 = 271\text{mm}^2$

Provide 50X50X4 @3kg/m Area = 388mm², $r_y = 9.7$

$l/r_y = 2000/9.7 = 206.18 > 120$ and < 250

$\therefore Kl/r_y = 46.2 + 0.612 (l/r_y) = 172.38 < 250$

Ok

Then $(b_1+b_2)/2t = (50+50)/(2*4) = 12.5$

And $\epsilon = 1.0$ and $\epsilon (3.14^2 E/250)^{0.5} = 88.86$

$\lambda_v = (KL/r_y) / \epsilon (\pi^2 E/250)^{0.5} = 206.18/88.86 = 2.32$

$\lambda_{\phi} = [(b_1 + b_2)/2t] / \epsilon (\pi^2 E/250)^{0.5} = 12.5/88.86 = 0.14$

$\lambda_{\epsilon} = (k_1 + k_2 \lambda_v^2 + k_3 \lambda_{\phi}^2)^{0.5} = [0.20 + (0.35 * 2.32^2) + (20 * 0.14^2)]^{0.5} = 1.57$

$\phi = 0.5 [1 + \alpha(\lambda - 0.2) + \lambda^2] = 0.5 [1 + (0.49 * (1.57 - 0.2)) + 1.57^2] = 2.06$

And $\chi = 1 / [\phi + \sqrt{(\phi^2 - \lambda^2)}] = 1 / \sqrt{(2.06^2 - 1.6^2)} = 0.77$

And $f_{cd} = \chi f_y / \gamma_{mo} = (0.77 * 250) / 1.1 = 175 \text{ N/mm}^2$

$P_d = A_e \times f_{cd} = 388 * 175 = 17028 = 67.9 \text{ KN} > 29\text{KN}$

Hence Ok

Design of end connection

$V_{nsb} = V_{nsb} = (f_{ub} / \sqrt{3}) * (n_n A_{nb} + n_s A_{sb}) = 400 / \sqrt{3} * (1 * 314) = 72515 \text{ N}$

$V_{dsb} = 72515 / 1.25 = 58012 \text{ N}$

$e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*22), (60/(3*22)-0.25), 400/410, 1.0$

($e = 40, p = 60, d_0 = 22, f_{ub} = 400, f_u = 410$)

$K_h = \text{least of } [e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*22), (60/(3*22)-0.25), 400/410, 1.0]$

$K_h = 0.620$

$V_{npb} = 2.5 k_b d t f_u = 2.5 * 0.620 * 20 * 4 * 410 = 50840\text{N}$

$V_{dpb} = 50840 / 1.25 = 40672\text{N}$

No. of Bolts required = $(29*1000) / \text{least of } (58012 \text{ N}, 40672\text{N})$

= $(29000 / 40672) = 0.71 \approx 3$ bolts

Minimum number of bolts to be provided as per IS: 800-2007 is 2.

So, provide 3 black bolts of 20 mm diameter of spacing 50mm at end connection to gusset of 14mm thick. Edge distance = 40mm.

b) For Tension

Force = 12.53 KN

Factored Force = 1.5*12.53 = 18.79 KN = 20 KN

$Kl/r_y = 172.38 < 400$

Hence Ok

$V_{nsb} = (400/\sqrt{3})*(314) = 72515 \text{ N}$

$V_{dsb} = 72515 / 1.25 = 58012 \text{ N}$

$e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3*22), (60/(3*22)-0.25), 400/410, 1.0$

($e = 40, p = 60, d_0 = 22, f_{ub} = 400, f_u = 410$)

$K_h = \text{least of } [e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40 / (3*22), (60/(3*22)-0.25), 400/410, 1.0]$

$K_h = 0.620$

$V_{npb} = 2.5 k_b d t f_u = 2.5 * 0.620 * 20 * 4 * 410 = 50840\text{N}$

$V_{dpb} = 50840 / 1.25 = 40672\text{N}$

No. of Bolts required = $(20*1000) / \text{least of } (58012.6 \text{ N}, 40672\text{N})$

= $(20000 / 40672) = 0.4917 \approx 3$ bolts

Minimum number of bolts to be provided as per IS: 800-2007 is 2.

So, provide 3 black bolts of 20 mm diameter of spacing 50mm at end connection to gusset of 14mm thick. Edge distance = 40mm.

Design strength due to rupture

$L_c = 2*50 = 100\text{mm}$

$B_s = W + W_1 - L = 50 + 50 - 4 = 96\text{mm}$

$\beta = 1.4 - [0.076 (w/t) (f_y / f_u) (b_s / L_c)] \leq (f_y \gamma_{mo} / f_y \gamma_{m1})$

= $0.84 \leq 1.44$ and > 0.7

Ok

$T_{dn} = [\{0.9*(50-2-22)*4*410\} / 1.25] + [\{0.91*(50-2)*4*250\} / 1.1]$

= 69.3 KN

Design strength due to yielding

$$T_{dg} = (388 \times 250) / 1.1 = 88.18 \text{ KN}$$

Design Strength due to Block Shear

$$A_{vg} = (2 \times 50 + 40) \times 4 = 560 \text{ mm}^2$$

$$A_{vn} = (140 - 2.5 \times 22) \times 4 = 340 \text{ mm}^2$$

$$A_{tg} = (28 \times 4) = 112 \text{ mm}^2$$

$$A_{tn} = (28 - 0.5 \times 22) \times 4 = 68 \text{ mm}^2$$

$$T_{db1} = [(A_{vg} \times f_y) / (\gamma_{mo} \times \sqrt{3})] + [(0.9 \times A_{tn} \times f_u) / (\gamma_{m1})]$$

$$= [(560 \times 250) / (1.1 \times \sqrt{3})] + [(0.9 \times 68 \times 410) / (1.1)] = 96.2 \text{ KN}$$

$$T_{db2} = [(0.9 \times A_{vn} \times f_u) / (\gamma_{m1} \times \sqrt{3})] + [(A_{tg} \times f_y) / (\gamma_{mo})]$$

$$= [(0.9 \times 340 \times 410) / (1.25 \times \sqrt{3})] + [(112 \times 250) / 1.1] = 83.3 \text{ KN}$$

$$T_{db} = 83.3 \text{ KN}$$

Therefore $83.3 \text{ KN} > 20 \text{ KN}$

Hence Ok

5.1.6 Clamp Members (loaded through one leg)

a) For Compression

Force = 17.25 KN

Factored Force = $1.5 \times 17.25 = 26 \text{ KN}$

Initially assume KL/r as 100 and buckling class curve for single angle is 'c'.

Hence $f_{cd} = 107 \text{ N/mm}^2$.

Area required = $(26 \times 1000) / 107 = 242.9 \text{ mm}^2$

Provide 45X45X4

Area = 347 mm^2 , $r_v = 8.7$

$KL/r_v = (0.85 \times 2000) / 8.7 = 195.84 < 250$

Ok

Then $(b_1 + b_2) / 2t = (45 + 45) / (2 \times 3) = 15$

And $\epsilon = 1.0$ and $\epsilon (3.14^2 E / 250)^{0.5} = 88.86$

And $\lambda_v = (L/r_v) / \epsilon (\pi^2 E / 250)^{0.5} = 230 / 88.86 = 2.58$

And $\lambda_{\phi} = [(b_1 + b_2) / 2t] / \epsilon (\pi^2 E / 250)^{0.5} = 15 / 88.86 = 0.168 = 0.16$

And $\lambda_e = (k_1 + k_2 \lambda_v^2 + k_3 \lambda_{\phi}^2)^{0.5} = [0.20 + (0.35 \times 2.58^2) + (20 \times 0.16^2)]^{0.5} = 1.79$

$\phi = 0.5 [1 + \alpha(\lambda - 0.2) + \lambda^2] = 0.5 [1 + (0.49 \times (1.74 - 0.2)) + 1.74^2] = 2.39$

And $\chi = 1 / [\phi + \sqrt{(\phi^2 - \lambda^2)}] = 1 / \sqrt{(2.39^2 - 1.79^2)} = 0.63$

And $f_{cd} = \chi f_y / \gamma_{mo} = (0.63 \times 250) / 1.1 = 143.18 \text{ N/mm}^2$

$P_d = A_e \times f_{cd} = 347 \times 143.18 = 50 \text{ KN} > 26 \text{ KN}$

Hence Ok

Design of end connection

$V_{nsb} = V_{nsb} = (f_{ub} / \sqrt{3}) \times (n_n A_{nb} + n_s A_{sb}) = (400 / \sqrt{3}) \times (1 \times 314) = 72515 \text{ N}$

$V_{dsb} = 72515 / 1.25 = 58012 \text{ N}$

$e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3 \times 22), (60/(3 \times 22) - 0.25), 400/410, 1.0$

($e = 40, p = 60, d_0 = 22, f_{ub} = 400, f_u = 410$)

$K_h = \text{least of } [e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3 \times 22), (60/(3 \times 22) - 0.25), 400/410, 1.0]$

$K_h = 0.620$

$V_{npb} = 2.5 k_b d t f_u = 2.5 \times 0.620 \times 20 \times 4 \times 410 = 50840 \text{ N}$

$V_{dpb} = 50840 / 1.25 = 40672 \text{ N}$

No. of Bolts required = $(26 \times 1000) / \text{least of } (58012 \text{ N}, 40672 \text{ N})$

= $(26000 / 40672) = 0.63 \approx 3 \text{ bolts}$

Minimum number of bolts to be provided as per IS: 800-2007 is 2.

So, provide 3 black bolts of 20 mm diameter of spacing 60mm at end connection to gusset of 14mm thick. Edge distance = 40mm.

b) For Tension

Maximum Force = 15.22 KN

Factored Force = $1.5 \times 15.22 = 22.83 \text{ KN}$

$KL/r_v = 195.84 < 400$

Ok

$V_{nsb} = (400 / \sqrt{3}) \times (314) = 72515 \text{ N}$

$V_{dsb} = 72515 / 1.25 = 58012 \text{ N}$

$e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3 \times 22), (60/(3 \times 22) - 0.25), 400/410, 1.0$

($e = 40, p = 60, d_0 = 21.5, f_{ub} = 400, f_u = 410$)

$K_h = \text{least of } [e/3d_0, (p/3d_0 - 0.25), f_{ub}/f_u, 1.0 = 40/(3 \times 22), (60/(3 \times 22) - 0.25), 400/410, 1.0]$

$K_h = 0.620$

$V_{npb} = 2.5 k_b d t f_u = 2.5 \times 0.620 \times 20 \times 4 \times 410 = 50840 \text{ N}$

$V_{dpb} = 50840 / 1.25 = 40672 \text{ N}$

No. of Bolts required = $(22.83 \times 1000) / \text{least of } (58041 \text{ N}, 40672 \text{ N})$
 = $(22830 / 40672) = 0.56 \approx 3$ bolts

Minimum number of bolts to be provided as per IS: 800-2007 is 2.

So, provide 3 black bolts of 20 mm diameter of spacing 60mm at end connection to gusset of 14mm thick. Edge distance = 40mm.

Design strength due to rupture

$$L_c = 2 \times 60 = 120 \text{ mm}$$

$$B_s = W + W_1 - L = 45 + 25 - 4 = 67 \text{ mm}$$

$$\beta = 1.4 - [0.076 (w/t) (f_y / f_u) (b_s / L_c)] \leq (f_y \gamma_{mo} / f_y \gamma_{m1})$$

$$= 1.11 < 1.44 \text{ and } \geq 0.7 \quad \text{Ok}$$

$$T_{dn} = [\{0.9 \times (45 - 2 - 22) \times 4 \times 410\} / 1.25] + [\{1.11 \times (45 - 2) \times 4 \times 250\} / 1.1]$$

$$= 57.6 \text{ KN}$$

Design strength due to yielding

$$T_{dg} = (347 \times 250) / 1.1 = 78.86 \text{ KN}$$

Design Strength due to Block Shear

$$A_{vg} = (2 \times 60 + 40) \times 4 = 640 \text{ mm}^2$$

$$A_{vn} = (160 - 2.5 \times 22) \times 4 = 420 \text{ mm}^2$$

$$A_{tg} = (25 \times 4) = 100 \text{ mm}^2$$

$$A_{tn} = (25 - 0.5 \times 22) \times 4 = 56 \text{ mm}^2$$

$$T_{db1} = [(A_{vg} \times f_y) / (\gamma_{mo} \times \sqrt{3})] + [(0.9 \times A_{tn} \times f_u) / (\gamma_{m1})]$$

$$= [(640 \times 250) / (1.1 \times \sqrt{3})] + [(0.9 \times 56 \times 410) / (1.1)] = 102.6 \text{ KN}$$

$$T_{db2} = [(0.9 \times A_{vn} \times f_u) / (\gamma_{m1} \times \sqrt{3})] + [(A_{tg} \times f_y) / (\gamma_{mo})]$$

$$= [(0.9 \times 420 \times 410) / (1.25 \times \sqrt{3})] + [(100 \times 250) / 1.1] = 94.2 \text{ KN}$$

$$T_{db} = 94.2 \text{ KN}$$

Therefore $57.6 \text{ KN} > 22.83 \text{ KN}$

Hence Ok

5.2 OPTIMUM DESIGN BY STAAD-PRO V6i

5.2.1 The tower was designed by STAAD for obtaining optimum weight of tower so as to meet the objective of optimum design. IS: 800 (LSM) is selected for design. The type of section chosen was Angle section for all members. The parameters such as diameter of bolt, edge distance, pitch, yield strength, ultimate strength, and slenderness ratios were defined. Then the option "SELECT OPTIMIZED" was selected for arriving at optimum sections. Then the option "STEEL TAKE OFF" was selected for obtaining the details of sections assigned to the members and their weights. The details of the allotted steel angle sections for the members in the output of STAAD design were tabulated in the Table 2.

5.2.2 Considering the sections in Table 2, the corresponding lengths and weights are tabulated in Table 3. The total weight of the tower is also calculated. **Total Weight of Tower = 2.5221 Metric Tonnes**. As per reference [1] the weight of 132 KV DC tower for a span of 320 m span the weight of tower is 2.8 Metric Tons and is stated that 20% reduction can be possible with computer aided design. So, for a span of 330 m, as in our study, 2.5221 Metric Tons is an Optimum Weight of the tower. Design by IS: 800(1984) was also done by using STAAD and the weight of tower was found to be **2.8341 Metric Tonnes** which indicates 12% saving by LSM. Hence the objective of Optimum Design has been met.

Table 2: Member- Sections Details (STAAD PRO)

1	2	3	4	5	6
ISA60X40X5	ISA40X40X3	ISA100X100X6	ISA130X130X8	ISA40X40X3	ISA90X90X6
7	8	9	10	11	12
ISA40X40X6	ISA130X130X8	ISA65X65X3	ISA150X150X10	ISA40X40X6	ISA130X130X8
13	14	15	16	17	18
ISA35X35X3	ISA70X70X5	ISA45X45X5	ISA130X130X8	ISA45X30X3	ISA65X65X5
19	20	21	22	23	24
ISA45X45X5	ISA130X130X8	ISA45X45X3	ISA60X60X5	ISA75X75X5	ISA130X130X8
25	26	27	28	29	30
ISA50X50X4	ISA50X50X3	ISA50X50X5	ISA50X50X4	ISA45X45X3	ISA60X60X5
31	32	33	34	35	36
ISA40X40X4	ISA40X40X3	ISA45X30X3	ISA50X50X5	ISA45X30X3	ISA40X40X3
37	38	39	40	41	42
ISA45X45X3	ISA50X50X3	ISA50X50X3	ISA50X50X3	ISA30X30X5	ISA90X90X6
43	44	45	46	47	48
ISA80X80X6	ISA75X75X5	ISA65X65X5	ISA50X50X3	ISA80X80X6	ISA45X45X3
49	50	51	52	53	54
ISA80X80X6	ISA45X45X3	ISA80X80X6	ISA90X90X6	ISA30X30X3	ISA60X60X5
55	56	57	58	59	60
ISA60X60X5	ISA80X80X6	ISA90X90X6	ISA80X80X6	ISA90X90X6	ISA80X80X6
61	62	63	64	65	66
ISA45X45X3	ISA90X90X6	ISA40X40X3	ISA80X80X6	ISA40X40X3	ISA100X100X6
67	68	69	70	71	72
ISA70X70X5	ISA35X35X3	ISA40X40X3	ISA65X65X5	ISA60X60X5	ISA30X30X3
73	74	75	76	77	78
ISA30X30X3	ISA45X45X3	ISA40X40X3	ISA50X50X3	ISA40X40X3	ISA30X30X3
79	80	81	82	83	84
ISA40X40X3	ISA45X45X3	ISA50X50X3	ISA30X30X3	ISA40X40X3	ISA60X60X5
85	86	87	88	89	90
ISA60X60X5	ISA40X40X3	ISA50X50X3	ISA40X40X3	ISA40X40X3	ISA30X30X3
91	92	93	94	95	96
ISA40X40X3	ISA45X45X3	ISA40X40X3	ISA45X45X3	ISA30X30X3	ISA45X45X3
97	98	99	100	101	102
ISA45X30X3	ISA60X60X5	ISA80X80X6	ISA60X60X5	ISA60X60X5	ISA80X80X6
103	104	105	106	107	108
ISA80X80X6	ISA100X100X6	ISA90X90X6	ISA90X90X6	ISA70X70X5	ISA65X65X5
109	110	111	112	113	114
ISA100X100X6	ISA100X100X6	ISA90X90X6	ISA90X90X6	ISA80X80X6	ISA90X90X6
115	116	117	118	119	120
ISA80X80X6	ISA90X90X6	ISA80X80X6	ISA60X60X5	ISA60X60X5	ISA45X45X3
121	122	123	124	125	126
ISA80X80X6	ISA45X45X3	ISA80X80X6	ISA40X40X5	ISA35X35X6	ISA40X25X5
127	128	129	130	131	132
ISA40X40X3	ISA45X45X3	ISA60X60X5	ISA30X30X5	ISA25X25X4	ISA40X40X3
133	134	135	136	137	138
ISA40X40X3	ISA40X40X3	ISA40X40X3	ISA40X40X3	ISA40X40X3	ISA40X40X3
139	140	141	142	143	144
ISA40X40X3	ISA40X40X3	ISA40X40X3	ISA40X40X3	ISA45X45X3	ISA45X45X3
145	146	147	148	149	150
ISA45X45X3	ISA35X35X3	ISA65X65X5	ISA50X50X4	ISA45X45X4	ISA45X45X3
151	152	153	154	155	156
ISA45X45X3	ISA60X60X5	ISA60X60X5	ISA60X40X5	ISA100X75X6	ISA65X65X5
157	158	159	160	161	162
ISA50X50X3	ISA45X45X6	ISA90X90X6	ISA70X70X5	ISA60X60X5	ISA65X45X5
163	164	165	166	167	168
ISA100X100X6	ISA80X80X6	ISA70X70X5	ISA70X45X5	ISA100X100X6	ISA75X75X5
169	170	171	172	173	174
ISA100X100X6	ISA100X100X6	ISA100X100X6	ISA100X100X6	ISA100X100X6	ISA70X45X5
175	176	177	178	179	180
ISA100X100X6	ISA90X90X6	ISA90X90X6	ISA90X90X6	ISA90X90X6	ISA45X45X3
181	182	183	184	185	186
ISA90X90X6	ISA35X35X3	ISA75X75X5	ISA60X60X5	ISA45X30X3	ISA50X50X4
187	188	189	190	191	192
ISA45X45X3	ISA187	ISA188	ISA189	ISA190	ISA191
ISA45X45X3	ISA50X50X4	ISA45X45X3	ISA45X45X3	ISA50X50X3	ISA65X65X5
193	194	195	196	197	198
ISA60X60X5	ISA70X70X5	ISA70X70X5	ISA80X80X6	ISA75X75X5	ISA35X35X3
199	200	201	202	203	204
ISA70X70X5	ISA35X35X3	ISA90X90X6	ISA60X60X5	ISA30X30X3	ISA45X45X3
205	206	207	208	209	210
ISA50X50X3	ISA45X45X3	ISA30X30X3	ISA25X25X3	ISA70X70X5	ISA45X45X3
211	212	213	214	215	216
ISA45X45X3	ISA70X70X5	ISA90X90X6	ISA90X90X6	ISA75X75X5	ISA75X75X5
217	218	219	220	221	222
ISA60X60X5	ISA50X50X3	ISA50X50X3	ISA60X60X5	ISA40X40X4	ISA40X40X3
223	224	225	226	227	228
ISA45X30X3	ISA50X50X5	ISA45X30X3	ISA40X40X3	ISA45X45X3	ISA50X50X3
229	230	231	232	233	234
ISA50X50X3	ISA50X50X3	ISA30X30X3	ISA25X25X4	ISA40X40X3	ISA50X50X3
235	236	237	238	239	240
ISA40X40X3	ISA40X40X3	ISA40X40X3	ISA40X40X3	ISA40X40X3	ISA45X45X3
241	242	243	244	245	246
ISA45X45X3	ISA40X40X3	ISA50X50X3	ISA40X40X3	ISA40X40X3	ISA45X45X3
247	248	249	250	251	252
ISA50X50X3	ISA40X40X3	ISA30X30X3	ISA40X40X3	ISA40X40X3	ISA50X50X3
253	254	255	256	257	258
ISA40X40X3	ISA40X40X3	ISA40X40X3	ISA45X45X3	ISA40X40X3	ISA45X45X3
259	260				
ISA45X45X3	ISA45X30X3	ISA45X30X3			

Table 3: Section – Weight Details (STAAD PRO)

PROFILE	LENGTH(METER)	WEIGHT(KN)
ST ISA60X40X5	5.09	0.186
ST ISA40X40X3	59.51	1.070
ST ISA100X100X6	29.88	2.679
ST ISA130X130X8	15.26	2.371
ST ISA90X90X6	57.97	4.663
ST ISA40X40X6	5.09	0.175
ST ISA65X65X5	21.08	1.012
ST ISA150X150X10	5.01	1.118
ST ISA35X35X3	14.40	0.224
ST ISA70X70X5	26.14	1.359
ST ISA45X45X5	5.09	0.167
ST ISA45X30X3	11.42	0.191
ST ISA45X45X3	60.86	1.234
ST ISA60X60X5	42.16	1.862
ST ISA75X75X5	19.72	1.102
ST ISA50X50X4	7.71	0.230
ST ISA50X50X3	29.21	0.662
ST ISA50X50X5	4.00	0.147
ST ISA40X40X4	2.50	0.059
ST ISA30X30X5	4.50	0.096
ST ISA80X80X6	47.31	3.376
ST ISA30X30X3	20.14	0.268
ST ISA40X40X5	1.50	0.044
ST ISA35X35X6	1.50	0.044
ST ISA40X25X5	1.50	0.035
ST ISA25X25X4	2.50	0.035
ST ISA45X45X4	1.50	0.040
ST ISA100X75X6	2.54	0.198
ST ISA45X45X6	2.54	0.099
ST ISA65X45X5	2.54	0.103
ST ISA70X45X5	7.63	0.324
ST ISA40X25X3	2.02	0.029
ST ISA25X25X3	1.74	0.019
TOTAL		25.221

Total Weight of Tower (LSD) = 2.5221 Metric Tons.

VI. CONCLUSION

The present study envisages the static analysis of the Four-Legged Square shaped 132 KV Double Circuit Steel Transmission Line Tower for all possible load combinations including wind. Maximum X-displacement = 63.1698 mm at clamp node under load combination 1. Maximum Y-displacement = 15.9 mm at top cross arm nodes under load combination 1. Maximum Z- displacement =9.3mm at clamp node under load combination 2.

The maximum displacements i.e.; X- displacement = 63.1698 mm was caused due to Dead and Wind load (Load Combination1). Hence, the Ground Wire Broken condition (Load Combination 2) and Conductor Broken condition (Load Combination 3) had less affect on the chosen tower of 21m height, horizontal length of cross arm of 3m and 2 m hammer width. It can be stated that with increase in height, length of cross arm members and hammer width, the twisting action due to conductor broken condition and bending action of Ground Wire broken condition may affect the structure but bending action due to wind load plays vital role. Hence Wind load is major load for towers.

As per the knowledge of the author, the available literature/research works as per Indian standards on towers till date have been focused on working stress method which does not yield optimum section as strength beyond proportionality limit and local yielding was neglected. There is an urgent need to arrive at an optimum design procedure of towers, as these structures are frequently constructed. Limit State methodology is a rational method which provides optimum design i.e.; optimum sections.

Hence the tower was designed by Limit State Methodology as per IS: 800-2007 rather than the conventional working stress methodology, both manually and by STAAD PRO V6i, for obtaining optimized design. Design by IS: 800-1984(WSM) was also carried out in STAAD. The weight of the tower by LSM was 2.5221Metric Tonnes and by WSM was 2.8341 Metric Tonnes resulting in 12% saving by LSM. Thus, the objectives of understanding the behaviour of tower under wind load in combination with other loads and obtaining optimized design by Limit State methodology, in this study, were realized.

REFERENCES

- [1]. S.S.Murthy and A.R.Santhakumar, *Transmission Line Structures* (McGraw-Hill, 1990).
- [2]. K.S.Sai Ram, *Design of Steel Structures* (Pearson, 2015).
- [3]. N. Subramanian, *Design of Steel Structures* (Oxford, 2008).
- [4]. G. Visweswara Rao, Optimum Designs For Transmission Line Towers, *Computers & Structures, Pergamon, Elsevier, Volume- 57, Issue- I, 1995, 81-92.*
- [5]. K. Natarajan and A. R. Santhakumar, Reliability Based Optimization of Transmission Line Towers, *Computers & Structures, Pergamon, Elsevier, Volume- 55, Issue- 3, 1995, 387-403.*
- [6]. T. Raghavendra, Computer Aided Analysis and Structural Optimization of Transmission line tower, *International Journal of Advanced Engineering Technology, Vol.III, Issue III, July-Sept 2012, 44-50.*
- [7]. V. Lakshmi and A. Rajagopala Rao, Effect of medium wind intensity on 21M -132kV Transmission Tower, *International Journal of Engineering Science & Advanced Technology, Volume-2, Issue-4, July-August 2012, 820 – 824.*
- [8]. Y. M. Ghugal and U. S. Salunkhe, Analysis and design of three and four legged 400kv steel transmission line tower, *International Journal of Earth Sciences and Engineering, Volume 04, No 06 SPL, October 2011, 691-694.*
- [9]. A.Jesumi and M.G.Rajendran, Optimal Bracing System for Steel Towers, *International Journal of Research and Applications, Volume 3, Issue 2, March-April 2013, 729-732.*
- [10]. C. Preethi and K. Jagan Mohan, Analysis of Transmission Towers with Different Configurations, *Jordan Journal of Civil Engineering, 2013, Volume 7, Issue 4.*
- [11]. IS: 398, Aluminum conductors for overhead transmission purposes, *Bureau of Indian Standards, New Delhi, 1 961.*
- [12]. IS: 2141, Hot-Dip Galvanized Stay strand, *Bureau of Indian Standards, New Delhi, 1968.*
- [13]. Indian Electricity Rules, Ministry of Irrigation and Power, New Delhi, India, 1956.
- [14]. IS: 802, Use of structural steel in overhead transmission line towers, *Bureau of Indian Standards, New Delhi, 1 995.*
- [15]. IS: 875(III), Code of practice for Design Loads (other than Earth Quake) for Buildings and Structures, *Bureau of Indian Standards, New Delhi, 1989.*
- [16]. IS 731, Specification for Porcelain Insulators. *Bureau of Indian Standards, New Delhi, 1971*
- [17]. IS 3188, Characteristics of String Insulator Units, *Bureau of Indian Standards, New Delhi, 1980.*
- [18]. IS: 800, General Construction in Steel-Code of Practice, *Bureau of Indian Standards, New Delhi, 2007*